

**Statement of Pre-Bid Queries received from the prospective bidder in respect of Tender Notice No.HIGH COURT/UPS/337/2023 dated 09/08/2023**

**Meeting date 23/08/2023 (Through Video Conferencing)**

Sr. No.	Name of the Company	Tender Section No.	Tender Page No.	Tender Clause No	Existing Clause details	Clarification Sought	Reply of the Committee
1	Ace Brain Systems & Software Pvt. Ltd.	1.48: Installation Process	31	1.48.2	Maximum Period for Delivery from the date of Purchase Order: 4 Weeks	Kindly extend to 8 Weeks, due to market conditions and chip shortages the delivery of product is delayed.	No change
2	Ace Brain Systems & Software Pvt. Ltd.	1.49: Payment Process	34	1.49.3	100% payment will be made after satisfactory delivery, installation and commissioning thereof.	Kindly make it 90% against Delivery and Balance against installation. As installation can be delayed due to various reasons.	No change
3	Microtech International	Annexure 9 Main Technical MT.01 Item No.1 UPS 600VA Sr.No. 20	55	Annexure 9 Main Technical MT.01 Item No.1 UPS 600VA Sr.No. 20	Backup Time : 40 Min.	Bidder orally requested to change.	Delete clause No.20
4	Microtech International	Annexure 9 Main Technical MT.01 Item No.2 Online UPS 200KVA Sr.No. 27	57	Annexure 9 Main Technical MT.01 Item No.2 Online UPS 200KVA Sr.No. 27	Compatibility : D/G set and Solar Power	Bidder orally requested to remove Solar Power	Remove "Solar Power"
5	Microtech International	Annexure 9 Main Technical MT.01 Item No.2 Online UPS 200KVA Sr.No. 49	59	Annexure 9 Main Technical MT.01 Item No.2 Online UPS 200KVA Sr.No. 49	SNPM Support : Card Required	Bidder orally requested to change.	Change as "Support SNMP : Card Required.
6	Microtech International	Annexure 9 Main Technical MT.01 Item No.1 UPS 600VA Sr.No.15	54	Annexure 9 Main Technical MT.01 Item No.1 UPS 600VA Sr.No.15	Backup Time : 15 minutes on full load of 0.6 PF 8 VAH	Bidder orally requested to remove 8 VAH	Remove "8 VAH"
7	Microtech International	Annexure 9 Main Technical MT.01 Item No.2 Online UPS 200KVA Sr.No. 36	58	Annexure 9 Main Technical MT.01 Item No.2 Online UPS 200KVA Sr.No. 36	Transient Response Time : For 100% load change, output will remain within $\pm 1\%$ and recovery within 20 ms.	Bidder orally requested to change $\pm 10\%$ and recovery within 100 ms.	Change as " $\pm 10\%$ and recovery within 100 ms"