

HIGH COURT OF JUDICATURE AT BOMBAYCorrigendum - I

Read :- 1) Tender Notice No. HIGH COURT/UPS/337/2023 dated 09/08/2023

Tender ID : 2023\_BHCMU\_934269\_1

Corrigendum Type : Technical Corrigendum

Amendments made in Tender Document are highlighted in bold letters.

Sr. No.	Clause No. in Tender Document	Clause as per Tender Document	Amendments
1)	Page No. 55 Annexure – 9: Main Technical MT.01, Item No. 1: UPS 600VA Sr. No. 20	Backup Time: 40 Min.	The clause “Backup Time: 40 Min.” is <b>deleted</b> .
2)	Page No. 57 Annexure – 9: Main Technical MT.01, Item No. 2: Online UPS 200KVA Sr. No. 27	Compatibility: D/G set and Solar Power	The words “and Solar Power” are <b>deleted</b> .
3)	Page No. 59 Annexure – 9: Main Technical MT.01, Item No. 2: Online UPS 200KVA Sr. No. 49	SNPM Support: Card Required	The clause “SNPM Support: Card Required” is changed as <b>“Support SNMP: Card Required”</b>
4)	Page No. 54 Annexure – 9: Main Technical	Backup Time : 15 minutes on full load of 0.6 PF 8 VAH	The words “8 VAH” are <b>deleted</b> .

Sr. No.	Clause No. in Tender Document	Clause as per Tender Document	Amendments
	MT.01, Item No. 1: UPS 600VA Sr. No. 15		
5)	Page No. 58 Annexure – 9: Main Technical MT.01, Item No. 2: Online UPS 200KVA Sr. No. 36	Transient Response Time: For 100% load change, output will remain within $\pm 1\%$ and recovery within 20 ms.	The clause “Transient Response Time: For 100% load change, output will remain within $\pm 1\%$ and recovery within 20 ms.” is changed as <b>“Transient Response Time: For 100% load change, output will remain within <math>\pm 10\%</math> and recovery within 100 ms”</b>
6)	Page No. 74 Annexure – 16: Blank Technical verification Data Sheets (TVDS), Item No. 1: UPS 600VA Sr. No. 20	Backup Time: 40 Min.	The clause “Backup Time: 40 Min.” is <b>deleted</b> .
7)	Page No. 76 Annexure – 16: Blank Technical verification Data Sheets (TVDS), Item No. 2: Online UPS 200KVA Sr. No. 27	Compatibility: D/G set and Solar Power	The words “and Solar Power” are <b>deleted</b> .
8)	Page No. 78 Annexure – 16: Blank Technical verification Data Sheets (TVDS), Item No. 2: Online UPS	SNMP Support: Card Required	The clause “SNMP Support: Card Required” is changed as <b>“Support SNMP: Card Required”</b>

Sr. No.	Clause No. in Tender Document	Clause as per Tender Document	Amendments
	200KVA Sr. No. 49		
9)	Page No. 73 Annexure – 16: Blank Technical verification Data Sheets (TVDS), Item No. 1: UPS 600VA Sr. No. 15	Backup Time : 15 minutes on full load of 0.6 PF 8 VAH	The words “8 VAH” are <b>deleted.</b>
10)	Page No. 77 Annexure – 16: Blank Technical verification Data Sheets (TVDS), Item No. 2: Online UPS 200KVA Sr. No. 36	Transient Response Time: For 100% load change, output will remain within $\pm 1\%$ and recovery within 20 ms.	The clause “Transient Response Time: For 100% load change, output will remain within $\pm 1\%$ and recovery within 20 ms.” is changed as “ <b>Transient Response Time: For 100% load change, output will remain within <math>\pm 10\%</math> and recovery within 100 ms</b> ”

High Court of Judicature at Bombay ]

] ]

] ]

] ]

Date: 25<sup>th</sup> August 2023 ]

Sd/-

Registrar General